

**Government of Bihar
Public Health Engineering Department, Nawada
Water Quality Report**

District: Nawada		Sample Collected on 07.04.2022 by Vijay Kumar (Guard) V.P. School & Received in the Laboratory on 07.04.2022																				
Sl. No.	Block	PANCHAYAT	VILLAGE	NEAREST PERSON	Latitude	Longitude	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₂	CO ₂	F	As	T. coli	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	
1	Warisaleganj	Warisaleganj	Warisaleganj	Vivekanand Public School, Warisaleganj			7.26	-	230	151	110	24	12.00	15	140	0.1	12.5	11	0.95	-	-	
Desirable Limit*							6.5-8.5	1.0		500	200	75	30	250	200	10	45	150	1.0	0.01		
Permissible Limit* in absence of alternate source							NR	5.0		2000	600	200	100	1000	500	NR	NR	400	1.5	0.05		≤ 1.1

Jyoti Khatke
25.04.22

(Kumar)
25.04.2022
Chemist
P.H. Division, Nawada

Jyoti Khatke

Jyoti Khatke